





**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Seneca County
Walnut Grove Campground 2
TNC Water System
PWSID: OH7448512
STUID: 7458188

December 14, 2011

CERTIFIED MAIL

Ms. Christine Rubeck
Walnut Grove Campground
7325 South Township. Road 131
Tiffin, Ohio 44883

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

This letter is notification that the Walnut Grove Campground 2 has not complied with requirements issued during this Agency's last survey performed on May 7 2011, in violation of rule 3745-81-60 of the Ohio Administrative Code. The system was notified in correspondence dated May 24, 2011, to respond in writing no later than 30 days, with time frames for:

1. Replace the conduit connection to the well cap. The connection shall be threaded and sealed to prevent the entrance of insects and water. [OAC Rule 3745-9-05(P)]
2. Ensure that backflow prevention devices are tested every 12 months. [OAC Rule 3745-95-06]

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions, please contact me at 419-373-3107 or elizabeth.ames@epa.state.oh.us.

Sincerely,

Elizabeth Ames
Environmental Specialist 2
Division of Drinking and Ground Waters

/llr

pc: Seneca County Health Department
Central Office, DDAGW
Certified Mail Receipt Number 7009 1410 0001 1834 1231

