





**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Crawford County
Evangelical Nazareth Lutheran Church
Transient Non-Community
Public Water System
PWS ID# OH1732412
STU ID# 1753679

January 24, 2012

Pastor and Council
Evangelical Nazareth Lutheran Church
6411 State Route 4
P. O. Box 68
Chatfield, Ohio 44825

Dear Pastor and Council:

On November 18, 2011, I received a letter from Trustee Brad Kirgis in response to my October 18, 2011, report regarding the September 29, 2011, sanitary survey of the Evangelical Nazareth Lutheran Church's public water system.

The survey report required re-grading of the area around the well so that surface water would drain away from the casing. Mr. Kirgis' letter stated this work was completed on October 5, 2011, and including a photo documenting the work.

Thank you for your prompt response to this matter. No further response is required.

Please be advised that my colleague, Janis D'Amico has recently taken over responsibility for public water systems in Crawford County. If you have any questions regarding this letter, or any other matter involving your water system, please contact Ms. D'Amico at 419-373-3108 or via email at Janis.Damico@epa.state.oh.us.

Sincerely,



Kimberly K. Burnham, R.S.
Environmental Specialist 2
Division of Drinking and Ground Waters

/llr

pc: Crawford County Health Department
Andy Barienbrock, DDAGW, Operations CO
DDAGW, NWDO File

ec: Janis D'Amico, DDAGW, NWDO

