



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Allen County
LaFayette Congregational Christian Church
TNC Public Water System
PWS ID# OH0233312
STU ID# 252650

January 6, 2012

Mr. Jerry Maus, Moderator
LaFayette Congregational Christian Church
201 West Main Street
P. O. Box 7242
Lafayette, Ohio 45854

Dear Mr. Maus:

This letter is notification that the LaFayette Congregational Christian Church has returned to compliance with the requirements issued during this Agency's last survey performed on September 28, 2011.

Further review of the file and discussions with Paul Brock P.E., Engineering Supervisor, showed the peroxide feed system must have been omitted from the original plan approval issued by the director of the Ohio EPA, dated March 2, 2007. A carbon filter was added for additional taste and odor improvements to the water system and would have not been installed without an oxidant being fed before it.

To further improve your system, we recommend the hole in the top of the peroxide bottle be plug and the hole in the lid only be large enough to allow the tubing to be place through it. This will help eliminate the chances of insects and rodents from entering the bottle, as well as help to not degrade the peroxide.

If you have any questions, please contact me at 419-373-3089 or via email at jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Environmental Specialist
Division of Drinking and Ground Waters

/llr

pc: Allen County Health Department
Andy Barienbrock, CO - DDAGW/OFAS
DDAGW - NWDO File
ec: Paul Brock P.E., Engineering Supervisor, NWDO-DDAGW
Linda Benham, Supervisor, NWDO-DDAGW