



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



\* D D G W O H 6 2 4 7 4 1 2 8 3 8 4 1 0 5

December 6, 2011

**NOTICE OF VIOLATION – ACTION REQUIRED**

CERTIFIED MAIL

Mr. Michael Wodrich  
African Safari Wildlife  
267 Lightner Road  
Port Clinton, Ohio 43452

Ottawa County  
African Safari Wildlife  
Non-Community, Transient PWS  
PWS ID: OH6247412

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During Fourth Quarter of 2011 (ACUTE)**

African Safari Wildlife is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Water samples have confirmed the presence of *E. colifecal* coliform in the drinking water. *Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes.* This is an Acute MCL violation requiring immediate action.

**IMMEDIATE ACTION REQUIRED:**

- 1. Consult with Ohio EPA within 24 hours** regarding public notice requirements. If you have not already received direction regarding this violation, contact the NWDO at 419-373-3088..
- 2. Issue the enclosed public notice within 24 hours** in accordance with OAC, Rule 3745-81-32 using one or more of the following methods to reach all persons served.
  - Hand delivery to persons served by the water system fountains, vending areas
  - Send to parents or guardians of children at schools or day care facilities
  - Another delivery method approved in writing by the director
  - 
  - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking
  - Posted notices must remain in place for as long as the violation exists.
  - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven (7) days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.


Mr. Michael Wodrich  
December 6, 2011  
Page 2

**NOTE: Issuance of a Public Notice must be repeated every 30 days** for as long as the violation exists, unless directed otherwise by the District Office. A verification form and a copy of the public notice stating the corrective measures completed to date must be submitted to the Ohio EPA.

3. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
4. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NWDO. Include a copy of each notice distributed, published or posted.
5. **Discontinue the Water Use Advisory** – The water use advisory shall remain in effect until one set of four (4) repeat samples is total coliform-negative. Notify the people served by the water system when the water use advisory is discontinued.
6. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact this office at 419-373-3088.

Sincerely,



John A. (Jack) Schwartz  
Division of Drinking and Ground Waters

//lr

Enclosures: Tier 1 Public Notification (2)  
Public Notice Instructions and Verification Form

pc: Ottawa County Health Department  
Information Management Section, DDAGW, CO  
DDAGW – NWDO (w/enclosures)  
Certified Mail Receipt Number 7009 1410 0001 1834 1033

## **PUBLIC NOTICE- DRINKING WATER WARNING**

**Fecal coliform or *E. coli* bacteria were found in the African Safari  
Wildlife water supply**

**BOIL YOUR WATER BEFORE USING  
OR USE BOTTLED WATER**

Bottled water is available from \_\_\_\_\_.

### **What should I do?**

- *DO NOT DRINK THE WATER WITHOUT BOILING IT FIRST. Bring all water to a boil, let it boil for at least one minute, and let it cool before using, or use bottled water. Boiled or bottled water should be used for drinking, making ice, brushing teeth, washing dishes and food preparation until further notice. Boiling kills bacteria and other organisms in the water.*
- *Fecal coliforms and *E. coli* are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short term effects, diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, and people with severely compromised immune systems.*
- *The symptoms above are not caused only by organisms in drinking water. If you experience any of these symptoms and they persist, you may want to seek medical advice. People at increased risk should seek advice about drinking water from their health care providers.*

### **What is being done?**

We are investigating and taking the necessary steps to correct the problem as soon as possible.

For more information, please contact \_\_\_\_\_ at \_\_\_\_\_  
name of contact phone number

or at \_\_\_\_\_  
mailing address

General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1(800) 426-4791.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly. You can do this by posting this notice in a public place or distributing copies by hand or mail.*

PWS ID: OH6247412

Date this public notice was distributed:

## **PUBLIC NOTICE- DRINKING WATER WARNING**

**Fecal coliform or *E. coli* bacteria were found in the African Safari  
Wildlife water supply**

**BOIL YOUR WATER BEFORE USING  
OR USE BOTTLED WATER**

Bottled water is available from \_\_\_\_\_

### **What should I do?**

- *DO NOT DRINK THE WATER WITHOUT BOILING IT FIRST. Bring all water to a boil, let it boil for at least one minute, and let it cool before using, or use bottled water. Boiled or bottled water should be used for drinking, making ice, brushing teeth, washing dishes and food preparation until further notice. Boiling kills bacteria and other organisms in the water.*
- *Fecal coliforms and *E. coli* are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short term effects, diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, and people with severely compromised immune systems.*
- *The symptoms above are not caused only by organisms in drinking water. If you experience any of these symptoms and they persist, you may want to seek medical advice. People at increased risk should seek advice about drinking water from their health care providers.*

### **What is being done?**

We are investigating and taking the necessary steps to correct the problem as soon as possible.

For more information, please contact \_\_\_\_\_ at \_\_\_\_\_  
name of contact phone number

or at \_\_\_\_\_  
mailing address

General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1(800) 426-4791.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly. You can do this by posting this notice in a public place or distributing copies by hand or mail.*

PWS ID: OH6247412

Date this public notice was distributed:

## PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR TIER 1 VIOLATIONS

The owner or operator of a public water system with a Tier 1 violation or situation that may pose an acute risk to human health is required to notify the persons served by the public water system. Notice shall be issued as soon as practical but **no later than 24 hours** after the system learns of the violation. Public notice shall be repeated as established during consultation with Ohio EPA.

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW, AS DESCRIBED IN THE OHIO ADMINISTRATIVE CODE RULE 3745-81-32:

Required Method of Public Notification	Actual Method of Public Notification
<p><b>Use one or more of the following methods to reach all persons served by the public water system:</b></p> <ol style="list-style-type: none"> <li>1. Public notice issued by appropriate broadcast media (such as radio and television stations)</li> <li>2. Public notice issued by continuous posting in conspicuous places throughout the area served by the water system (required to remain posted for as long as the violation exists)</li> <li>3. Public notice issued by hand delivery to persons served by the water system</li> <li>4. Public notice issued by another delivery method approved in writing</li> </ol>	<p><b>Describe actual methods used to notify public of the violation:</b></p> <p>1A. Name of station(s) _____</p> <p>1B. Date provided to station(s) _____</p> <p>2A. Dates of posting _____</p> <p>2B. Locations of posting _____                      _____                      _____</p> <p>3. Date of delivery _____</p> <p>4A. Method _____</p> <p>4B. Date _____</p>
<p><b>Additional methods established in consultation with Ohio EPA</b></p>	<p>A. Method(s) _____                      _____</p> <p>B. Date(s) _____</p>

**Complete the enclosed verification form and mail it to Ohio EPA – NWDO. INCLUDE A COPY OF THE PUBLIC NOTICE.**

\_\_\_\_\_  
 Signature of Responsible Person                      Date

\_\_\_\_\_  
 Printed Name and Title of Responsible Person

African Safari Wildlife  
 OH6247412  
 Ottawa County  
 Fourth Quarter of 2011  
 Total Coliform Acute MCL (Vio. Type 21)

<p><b>For Ohio EPA use only:</b>                  Date PN received: _____                  PN acceptable: _____ PN not acceptable: _____</p>
--