



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



January 4, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

CERTIFIED MAIL

Mr. Jerry Maus, Moderator
Lafayette Congregational Church
205 W. Main Street, P.O. Box 7242
Lafayette, Ohio 45854

Allen County
Lafayette Congregational Christian Chu

TRANSIENT NON-COMMUNITY PWS
PWS ID: OH0233312

Dear Mr. Maus:

This letter is notification that the LaFayette Congregational Christian Church has not complied with requirements issued during this Agency's last survey performed on September 28, 2011, and therefore is in violation of rule 3745-81-60 of the Ohio Administrative Code(OAC). The church was notified in correspondence dated October 18, 2011, to respond in writing no later than 30 days, with time frames for:

- OAC Rule 3745-91-02(A) states, "No person shall begin construction or installation of a public water system, or make a substantial change in a public water system, until plans therefor have been approved by the director of environmental protection. An application for approval of plans for such construction, installation, or substantial change in a public water system, as required by section 6109.07 of the Revised Code, shall be submitted to the district office..."

A peroxide feed system was present during the survey and does not appear in the plan approval dated March 2, 2007 from the director of the Ohio EPA. Contact Paul Brock, Engineer of our office at 419-373-3152 regarding the discrepancy.

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions please call your Ohio EPA representative at 419-373-3089.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/llr

ec: DDAGW-NWDO AA (State Violation)
Certified Mail Receipt Number 7009 1410 0001 1843 7804

