




**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



January 5, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Gary Greiwe
1005 Harmon Street,
Findlay, Ohio 45840

Hancock County
Green Meadow MHP-Hancock Co
COMMUNITY PWS
PWS ID: OH3200812

Dear Public Water System Owner:

The Public Water System serving GREEN MEADOW MHP-HANCOCK CO is in violation of the Ohio Administrative Code (OAC) for failure to submit the following Monthly Operating Report(s) (MOR) required by OAC 3745-83-01 (I) and/or OAC 3745-81-75.

1. Language for MI (MOR Inadequate/Missing Content) Violation

Chlorine for Community PWS (frequency and concentration)

In accordance with Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1), community water systems are required to maintain a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system. OAC Rule 3745-83-01(G) (1) & (2) requires the public water system owner to monitor both the free and combined chlorine residuals at least once every day.

A review of October 2011 showed nine (9) days during the month a chlorine residual was not being maintained in the distribution system. Take steps to immediately correct this problem.

If you have any questions please call your Ohio EPA representative at 419-373-3089 or via email at jill.schiefer@epa.state.oh.us

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/llr

pc: DDAGW – NWDO File

