



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



December 28, 2011

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Nick Rettig
1857 Oakwood Road
Napoleon, Ohio 43545

Henry County
Henry County Regional W&SD
COMMUNITY PWS
PWS ID: OH3539212
STU: 3561990, 3562299

Dear Mr. Rettig:

The Public Water System serving HENRY COUNTY REGIONAL WSD is in violation of the Ohio Administrative Code (OAC) for failure to submit the following Monthly Operating Report(s) (MOR) required by OAC 3745-83-01 (I) and/or OAC 3745-81-75.

Notice of Violation – Monthly Report – Chlorine Residual

Chlorine for Community PWS

In accordance with Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1), community water systems are required to maintain a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system. OAC Rule 3745-83-01(G) (1) & (2) requires the public water system owner to monitor both the free and combined chlorine residuals at least once every day. Chlorine residual was not monitored on November 24, 25, 26, and 27, 2011.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to Chris.Riddle@epa.state.oh.us.

Sincerely,

Chris Riddle
Environmental Specialist 2
Division of Drinking and Ground Waters

/l/r

pc: Chris Diem, Operator
Henry County Health Department
DDAGW – NWDO File

ec: Julie Sidle, DDAGW- NWDO

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov

