



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



January 18, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. John Keys
228 North First Street
P. O. Box 457
Oakwood, Ohio 45873

Paulding County
Oakwood Village Water
Community PWS

PWS ID: OH6300312

Violation of the secondary standard for manganese - NOV OAC 3745-82-02

Dear Mr. Keys:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for manganese which is 0.05 mg/L. There were three (3) weeks during the month of December 2011, in which manganese exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for manganese are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01 (F)(6) to determine compliance with the secondary maximum contaminant level for manganese.
- (b) A public water system shall be in violation of the secondary standard for manganese when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for manganese does not require public notification. **Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.**

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to Chris.Riddle@epa.state.oh.us.

Sincerely,

Chris Riddle
Environmental Specialist 2
Division of Drinking and Ground Waters

/llr

pc: Paulding County Health Department
NWDO – DDAGW File
ec: Linda Benham, DDAGW, NWDO

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov

