

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Van Wert County
Pleasant Chapel United Methodist
Transient Non-Community
Public Water System
PWS ID# OH8133812
STU ID# 8159446

January 24, 2012

Mr. Robert Stemen, Trustee
9038 Old Tile Factory Road
Van Wert, Ohio 45891

Dear Mr. Stemen:


On January 12, 2012, I received a letter from you in response to my January 5, 2012, report regarding the December 29, 2011, sanitary survey of the Pleasant Chapel United Methodist Church's public water system.

The survey report required replacement of the unvented well cap with a cap that has a down-turned screened vent. Your letter stated this work was completed on January 10, 2012.

Thank you for your prompt response to this matter. I will stop by when I am in the area to photograph the well changes for our files. No further response is required.

If you have any questions regarding this letter, or any other matter involving your water system, please contact me at 419-373-3102 or via email at Kim.Burnham@epa.state.oh.us.

Sincerely,



Kimberly K. Burnham, R.S.
Environmental Specialist 2
Division of Drinking and Ground Waters

/llr

pc: Van Wert County Health Department
Andy Barienbrock, DDAGW, Operations CO
DDAGW, NWDO File

