



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Crawford County
St. Paul Lutheran Church
-North Robinson
Transient Non-Community
Public Water System
PWS ID# OH1733612
STU ID# 1753683

January 24, 2012

Pastor and Council
St. Paul Lutheran Church
2307 Main Street
P. O. Box 9
North Robinson, Ohio 44856

Dear Pastor and Council:

On July 18, 2011, I received a letter from Trustee Ronald Coleman in response to my June 29, 2011, report regarding the June 17, 2011, sanitary survey of the St. Paul Lutheran Church's public water system.

The survey report included two requirements. Following is a summary of Mr. Coleman's responses to these requirements:

1. A well cap with a downturned, screened vent was specified by Requirement 1. Mr. Coleman's letter stated the well cap had been replaced on June 29, 2011.
2. Requirement 2 required an air gap or other backflow prevention where the water softener backwash discharge line drains into the drain tile. Mr. Coleman's letter states he vented the tile to prevent back siphonage.


Thank you for your prompt response to these matters. No further response is required.

Please be advised that my colleague, Janis D'Amico has recently taken over responsibility for public water systems in Crawford County.

Pastor and Council
January 24, 2012
Page 2

If you have any questions regarding this letter, or any other matter involving your water system, please contact Ms. D'Amico at 419-373-3108 or via email at Janis.Damico@epa.state.oh.us.

Sincerely,



Kimberly K. Burnham, R.S.
Environmental Specialist 2
Division of Drinking and Ground Waters

//lr

pc: Crawford County Health Department
Andy Barenbrock, DDAGW, Operations CO
DDAGW, NWDO File

ec: Janis D'Amico, DDAGW, NWDO