



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 6, 2012

RE: CARROLL COUNTY  
ROCKWOOD PARK  
COMMUNITY WATER SYSTEM  
PWS ID # OH1000612

Rockwood Property Owners' Association  
Attention: Mr. Robert C. Prince  
5126 Monroe Drive, SW  
Carrollton, Ohio 44615

**NOTICE OF VIOLATION**

Dear Association:

This letter is notification that the Rockwood Park public water system (PWS) is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 milligrams/Liter (mg/L) free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the November 2011 Monthly Operating Report Form (MOR). The results indicated that on 22 days, the free chlorine residual was less than 0.2 mg/L free chlorine residual.

This office is requesting you provide an explanation of why these low residuals occurred. Please submit your response to this office within 30 days of the date of this letter.

Sincerely,

Cynthia M. Petretich  
Environmental Specialist II  
Division of Drinking and Ground Waters

CMP/ams

ec: Kim Ethers, Ohio EPA, NEDO, DDAGW

cc: John Dale Reed, Class A Operator & Vice President of the Association