



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 6, 2012

RE: CARROLL COUNTY  
PRIDE VALLEY MOBILE HOME PARK  
PWS ID # OH1000512  
COMMUNITY WATER SYSTEM

Mr. and Mrs. Dave Emery  
Pride Valley Mobile Home Park  
9147 Maple Street, Lot 7A  
Malvern, Ohio 44644

**NOTICE OF VIOLATION**

Dear Mr. and Mrs. Emery:

This letter is notification that the Pride Valley Mobile Home Park (MHP) public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 milligrams/Liter (mg/L) free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the November 2011 Monthly Operating Report Form (MOR). The results indicated that on 23 days, the free chlorine residual was less than 0.2 mg/L free chlorine residual.

This office is requesting you provide an explanation of why these low residuals occurred. Please submit your response to this office within 30 days of the date of this letter.

Sincerely,

Cynthia M. Petretich  
Environmental Specialist II  
Division of Drinking and Ground Waters

CMP/ams

ec: Kim Eppers, Ohio EPA, NEDO, DDAGW