



State of Ohio Environmental

OH1201312 CLEARVIEW MOBILE HOME PARK

36 11/30/07



401 East Fifth Street
Dayton, Ohio 45402-2911

Southwest Dis
TELE: (937)285-6357 FAX: (937)285-6358
www.epa.state.oh.us

Lee C. Cichon, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 4, 2007

**Subject: Clearview MHP
Clark County
Community Public Water System
PWS ID No. OH1201312**

Mr. Jeff Ulery, Owner
Clearview Mobile Home Park
Suburban Properties
3090 Possum Road
Springfield, Ohio 45502

Subject: Notice of Violation - Failure to comply with the disinfection requirements.

Dear Mr. Ulery:

The Clearview Mobile Home Park public water system is in violation of Chapter 6109 of the Ohio Revised Code (ORC) by failing to comply with the requirements for filtration and disinfection of surface water sources as set forth in Ohio Administrative Code (OAC) rules 3745-81-71 through 3745-81-75 and 3745-83-02.

The Clearview Mobile Home Park public water system violated OAC rule 3745-81-72 when the following disinfection requirements were not met during the month of January 2007, March 2007, and April 2007. The water system failed to provide sufficient disinfection treatment of its drinking water as outlined on the table below:

Date actual CT value during the maximum hourly flow rate did not meet or exceed the required minimum CT value as set forth in OAC Rule 3745-81-72
January 22, 2007
March 17, 2007
April 2 and 5, 2007

Mr. Jeff Ulery, Owner
September 4, 2007
Page 2

Actions required as a result of the above violation	
Step 1	<p>Within 30 days issue the attached public notice of the violation in accordance with OAC Rule 3745-81-32 by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none">1. Mail or other direct delivery to each customer receiving a bill and to other service connections; and2. If necessary, the system must also use any other method reasonably calculated to reach all persons served by the public water system; <p>The language in italics on the attached public notice is mandatory and must be included as written.</p>
Step 2	Initiate an investigation and take the necessary steps to correct the problem as soon as possible.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the Ohio EPA, Southwest District Office.

If you have any questions, please do not hesitate to call me at (937) 285-6118.

Sincerely,



Jeffery H. Stark
Division of Drinking and Ground Waters
Public Drinking Water Group

Enclosures

cc: Clark County Health Department
Mary McGuinn, Ohio EPA, DDAGW, SWDO
Charles Crosbie, Certified Operator w/enclosures

JHS\bp