



401 East Fifth Street  
Dayton, Ohio 45402-2911

Southwest District  
TELE: (937)285-6357 FAX  
www.epa.state.ohio.gov



Chris Korleski, Director

September 28, 2007

Mr. Jeff Ulery, Owner  
Clearview Mobile Home Park  
Suburban Properties  
3090 Possum Road  
Springfield, Ohio 45502

**Re: Clearview Mobile Home Park, Clark County, Community Public Water System, PWS ID# 1201312, Notice of Violation**

Dear Mr. Ulery:

The Clearview Mobile Home Park public water system is in violation of Chapter 6109 of the Ohio Revised Code (ORC) by failing to comply with the requirements for filtration and disinfection of surface water sources as set forth in Ohio Administrative Code (OAC) Rules 3745-81-71 through 3745-81-75 and 3745-83-02.

The Clearview Mobile Home Park public water system violated OAC Rule 3745-81-72 when the following disinfection requirements were not met during the month of July 2007. The water system failed to provide sufficient disinfection treatment of its drinking water as outlined on the table below:

Date actual CT value during the maximum hourly flow rate did not meet or exceed the required minimum CT value as set forth in OAC Rule 3745-81-72
July 12 and 28, 2007


Actions required as a result of the above violation	
Step 1	<p><b>Within 30 days</b> issue the attached public notice of the violation in accordance with OAC Rule 3745-81-32 by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> <li>1. Mail or other direct delivery to each customer receiving a bill and to other service connections; and</li> <li>2. If necessary, the system must also use any other method reasonably calculated to reach all persons served by the public water system;</li> </ol> <p>The language in italics on the attached public notice is mandatory and must be included as written.</p>

Mr. Jeff Ulery  
September 28, 2007  
Page 2

Step 2	Initiate an investigation and take the necessary steps to correct the problem as soon as possible.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the Ohio EPA, Southwest District Office.

If you have any questions, please do not hesitate to call me at (937) 285-6118.

Sincerely,



Jeffery H. Stark  
Division of Drinking and Ground Waters  
Public Drinking Water Group

cc: Clark County Health Department  
Mary McGuinn, Ohio EPA, DDAGW/SWDO  
Charles Crosbie, Certified Operator, w/enclosures

Enclosures

JHS/rlf