



State of Ohio Environment



* 0 H 1 2 0 1 3 1 2 9 6 5 8 2 0 7 *

Southwest District

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937)285-6357 FAX: (937)285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 24, 2007

Re: **Clearview MHP**
Clark County
Community Public Water System
PWS ID NO.: OH1101312

Mr. Jeff Ulery, Owner
Clearview Mobile Home Park
Suburban Properties
3090 Possum Road
Springfield, Ohio 45502

Subject: Notice of Violation - Failure to provide continuous chlorine and turbidity monitoring

The Clearview Mobile Home Park is in violation of Chapter 6109 of the Ohio Revised Code (ORC) by failing to comply with the requirements for filtration and disinfection of surface water sources set forth in Ohio Administrative Code (OAC) rules 3745-81-71 through 3745-81-75 and 3745-83-02.

The water system failed to continuously monitor (broken recorder) the residual disinfectant concentration of water entering its distribution system during the months of June 2006, July 2006, August 2006, September 2006, October 2006, November 2006, December 2006, and February 2007.

The water system failed to monitor the finished water for turbidity either continuously (broken recorder) or every four hours that the water treatment plant was in operation during the months of June 2006, July 2006, August 2006, September 2006, November 2006, December 2006, and February 2007.


OAC Rule 3745-81-32 requires the Clearview Mobile Home Park to notify persons served by its water system of its failure to perform the monitoring required by OAC Rule 3745-81-74 the Clearview Mobile Home Park must notify persons served by its water system of its failure to monitor by mail delivery or by hand delivery and by continuous posting in conspicuous places throughout the water system no later than thirty (30) days after the first monitoring violation occurs during a given month. Public notification of monitoring violations is only required to be issued once each month.

Mr. Jeff Ulery, Owner
Clearview Mobile Home Park
Suburban Properties
July 24, 2007
Page 2

Actions required as a result of the above violations	
Step 1	Within 30 days issue public notice of the violation in accordance with OAC Rule 3745-81-32 by the following methods: 1. Mail or other direct delivery to each customer receiving a bill and to other service connections; and; 2. If necessary, the system must also use any other method reasonably calculated to reach all persons. The language in italics on the attached public notice is mandatory and must be included as written.
Step 2	Within ten (10 days of completing Step 1 above, fill out the attached verification form and send along with a copy of the public notification issued to the Ohio EPA Southwest District Office.

If you have any questions, please contact me at (937) 285-6113.

Sincerely,



Jeffery H. Stark
Division of Drinking and Ground Waters
Public Drinking Water Group

cc: Clark County Combined Health District
Mary McGuinn, Ohio EPA, DDAGW, SWDO
Charles Crosbie, Certified Operator w/enclosures

JHS/plh