



Environmental
Protection Agency

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

OH1200412 CHATEAU ESTATES LTD.

5000

MR 02/23/10



February 23, 2010

RE: Chateau Estates MHP
Clark County
Community Public Water System
PWS ID NO. 1200412

Mr. Albert Turner II
P. O. Box 533
Centerville, Ohio 45441

Dear Mr. Turner:

This letter is notification that the *Chateau Estates* water system is in violation of the Ohio Administrative Code (OAC) for failure to perform lead and copper routine tap monitoring as specified in OAC rules 3745-81-80 through 3745-81-89.

This lead and copper routine tap monitoring was required during the June 1, 2009 – September 30, 2009 sampling period. Ohio EPA records indicate that Chateau Estates water system did not perform lead and copper monitoring during the required monitoring period.

In order to avoid any further violations, you must do the following:

1. Collect and analyze the required number of lead and copper tap samples during June 1, 2010 – September 30, 2010. Based on the reported population of 580, you are required to collect a minimum of 5 first draw lead and copper tap samples during each monitoring period listed above. Report results on the enclosed forms 5105, 5106, and 5107 by October 10, 2010.

2. **Within 30 days** issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following methods:

Mail or other direct delivery to each customer receiving a bill and to other service connections; and

If necessary, the system must also use any other method reasonably calculated to reach all persons served by the water system.

Mr. Albert Turner II
Chateau Estates MHP
February 23, 2010
Page 2

Note: Systems opting to include the required public notice in the next water bill have up to 90 days.

The language in italics on the attached public notice is mandatory and must be followed as written. If you have any questions, please contact me at (937) 285-6085.

Sincerely,

A handwritten signature in black ink that reads "Tya Darden". The signature is written in a cursive, flowing style.

Tya C. Darden
Environmental Specialist II
Division of Drinking and Ground Waters

Enclosures: Tier 3 Public Notification
Public Notice Instructions & Verification Form

cc: Clark County Health Department
Information Management Section, DDAGW, CO

TCD/bp

