




State of Ohio Environr OH2600603 LYONS VILLAGE 2950 02 05/12/08

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-2752
www.epa



NOTICE OF VIOLATION – ACTION REQUIRED

May 15, 2008

CERTIFIED MAIL

Lyons, Village of
Lyons Village
126 West Morenci St,
Lyons, OH 43533

Fulton County
Lyons Village
Public Community PWS
PWS ID: OH2600603
Facility ID: N/A

Subject: Violation of Maximum Contaminant Level for TOTAL TRIHALOMETHANES (TTHM)

Lyons Village is in violation for exceeding the maximum contaminant level (MCL) standard of 0.080 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-12 for TOTAL TRIHALOMETHANES (TTHM). Compliance with the MCL is based on a running annual average. The annual average for TOTAL TRIHALOMETHANES (TTHM) during the First Quarter of 2008 time period is 0.096 MG/L.

To address the MCL violation, Lyons Village is required to take the following actions:

1. Notify your customers within 30 days using the enclosed instructions and public notice.
2. Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
3. Perform quarterly monitoring for TOTAL TRIHALOMETHANES (TTHM) during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
4. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any existing enforcement action that has been issued to you.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Sarah Byerly
Division of Drinking and Ground Waters

Enclosure: Public Notice, Verification Form
cc: Manager; NWDO: DIV OF DRINKING AND GROUND WATER

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

DRINKING WATER NOTICE

Lyons Village Has Levels of TOTAL TRIHALOMETHANES (TTHM) Above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for TOTAL TRIHALOMETHANES (TTHM). The average level of TOTAL TRIHALOMETHANES (TTHM) over the last four quarters was 0.096 MG/L. The standard for TOTAL TRIHALOMETHANES (TTHM) is 0.080 MG/L.

What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing TOTAL TRIHALOMETHANES (TTHM) in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: _____

Phone Number: _____

Mailing Address: _____

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID: OH2600603 Facility ID: N/A Date Distributed: _____