



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-2752
www.epa.s

OH2860212

WEST GEUGA PLAZA-MAIN

6/7/2007



June 7, 2007

Re: Geauga County
West Geauga Plaza-Main PWS
Nontransient Noncommunity Public

Water System
CERTIFIED MAIL
91 7108 2133 3931 0973 8428

PWS ID: 2860212
STU ID: 2854500
SMP ID: EP001

West Geauga Plaza-Main
18355 Bent Tree Lane
Bainbridge Twp, OH 44023

RE: TETRACHLOROETHENE MAXIMUM CONTAMINANT LEVEL EXCEEDANCE

This letter is notification that your public water system is in violation of rule 3745-81-12 of the Ohio Administrative Code (OAC). West Geauga Plaza-Main PWS has exceeded the maximum contaminant level (MCL) for Tetrachloroethene within the January 1 through March 31, 2007 monitoring period.

Paragraph (D) of Rule 3745-81-12 establishes an MCL of 0.005 milligrams per liter (mg/L) for Tetrachloroethene Compliance with the MCL based on the running annual average of four consecutive quarters of samples. The running annual average for Tetrachloroethene for January 1 through March 31, 2007 is 0.013 mg/L.

As a result of this violation, rule 3745-81-32 of the OAC requires that a public notice be issued by your facility informing your consumers of the violation. Included with this violation is a public notice containing the mandatory health effects language that must appear in the notice. If you wish to make additional statements in the notice, this office must be contacted first. The public notice must be issued within 30 days as specified in the enclosed "Public Notice Instructions and Verification Form for Non Community Public Water Systems with Tier 2 Violations". Please complete and return this form along with a copy of the public notice, once it is issued.

West Geauga Plaza-Main public water system is required to continue monitoring according to your most recent monitoring schedule. For questions concerning the public notice requirement, please contact me at (614) 644-2752.

Sincerely,

Kenneth Baughman
Compliance Assurance Section
Division of Drinking and Ground Waters

Enclosures: Public Notice and Verification Form for Tier 2 violations

cc: Superintendent/Manager; NEDO, DDAGW; Geauga County Health Department; file

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director