



STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 644-2752  
www.epa.st



**NOTICE OF VIOLATION – ACTION REQUIRED**

August 14, 2009

CERTIFIED MAIL

91 7108 2133 3931 0972 3547

Jeffrey A Adams  
Chester Assoc C/O Channe  
7100 Wilson Mills Road,  
Chesterland, OH 44026

Geauga County  
Chester Assoc C/O Channe  
Non-Transient Non-Community PWS  
PWS ID: OH2861012  
Facility ID: 2854507

**Subject: Violation of Maximum Contaminant Level for ARSENIC**

Chester Assoc C/O Channe is in violation for exceeding the maximum contaminant level (MCL) standard of 0.010 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-11 for ARSENIC. Compliance with the MCL is based on a running annual average. The annual average for ARSENIC during the Second Quarter of 2009 time period is 0.014 MG/L.

To address the MCL violation, Chester Assoc C/O Channe is required to take the following actions:

1. Notify your customers within 30 days using the enclosed instructions and public notice.
2. Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
3. Perform quarterly monitoring for ARSENIC during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
4. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any existing enforcement action that has been issued to you.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Kathleen Pinto  
Compliance Assurance Section  
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form  
cc: Manager; DDAGW file; NEDO file; Geauga County Health Department

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

# DRINKING WATER NOTICE

## Chester Assoc C/O Channe Has Levels of ARSENIC Above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for ARSENIC. The average level of ARSENIC over the last four quarters was 0.014 MG/L. The standard for ARSENIC is 0.010 MG/L.

### What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

### What does this mean?

The levels detected do not pose an immediate risk to your health. However, Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer..

### What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: \_\_\_\_\_

Phone Number: \_\_\_\_\_

Mailing Address: \_\_\_\_\_

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

Date Distributed: \_\_\_\_\_

PWSID: OH2861012 Facility ID: 2854507

Monitoring Period: Second Quarter of 2009