



Environmental
Protection Agency

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Kordecki, Director

OH3400214 CADIZ VILLAGE PWS

2950 02 11/18/10



November 18, 2010

CERTIFIED MAIL

NOTICE OF VIOLATION – ACTION REQUIRED

Thomas H. Carter
Cadiz Village PWS
P.O. Box 153, 128 Court Street,
Cadiz, OH 43907

Harrison County
Cadiz Village PWS
Community PWS
PWS ID: OH3400214

Subject: Violation of Maximum Contaminant Level for TOTAL TRIHALOMETHANES (TTHM)

Cadiz Village is in violation for exceeding the maximum contaminant level (MCL) standard of 0.080 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-12 for TTHM. Compliance with the MCL is based on a running annual average. The annual average for TTHM during the Third Quarter of 2010 time period is 0.085 MG/L.

To address the MCL violation, Cadiz Village PWS is required to take the following actions:

1. Notify your customers within 30 days using the enclosed instructions and public notice.
2. Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
3. Perform quarterly monitoring for TTHM during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
4. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any existing enforcement action that has been issued to you.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Sarah Byerly
Compliance Assurance Section
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form
cc: Manager; DDAGW file; SEDO file; Harrison County Health Department

DRINKING WATER NOTICE

Monitoring requirements not met for Deer Lake Mobile Park

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the January 1, 2008 to December 31, 2010 time period we did not monitor for the following contaminants and therefore cannot be sure of the quality of our drinking water during that time: SIMAZINE, ATRAZINE, and ALACHLOR.

What Should I Do?

This notice is to inform you that Deer Lake Mobile Park did not monitor and report results for the presence of the contaminants listed above in the public drinking water system during the January 1, 2008 to December 31, 2010 time period, as required by the Ohio Environmental Protection Agency. You do not need to take any actions in response to this notice.

What Is Being Done?

Upon being notified of this violation, the water supply was required to have the drinking water analyzed for the above mentioned parameters. The water supplier will take steps to ensure that adequate monitoring will be performed in the future.

Additional information may be obtained by contacting Deer Lake Mobile Park at:

Contact Person: _____

Phone Number: _____

Mailing Address: _____

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID: OH2800612 Facility ID: 2854269

Date Distributed: _____