



Environmental
Protection Agency

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korteski, Director

OH3500711 HENRY COUNTY REGIONAL WSI 2456 02 11/18/10



* 0 H 3 5 0 0 7 1 1 8 7 4 6 7 2 4 *

November 18, 2010

CERTIFIED MAIL

NOTICE OF VIOLATION – ACTION REQUIRED

Nick Rettig
HCRW/SD-McClure System
1857 Oakwood Avenue,
Napoleon, OH 43545

Henry County
HCRW/SD-McClure System
Community PWS
PWS ID: OH3500711

Subject: Violation of Maximum Contaminant Level for TOTAL HALOACETIC ACIDS (HAA5)
HCRW/SD-McClure System is in violation for exceeding the maximum contaminant level (MCL) standard of 0.060 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-12 for HAA5. Compliance with the MCL is based on a running annual average. The annual average for HAA5 during the Third Quarter of 2010 time period is 0.086 MG/L.

To address the MCL violation, HCRW/SD-McClure System is required to take the following actions:

1. Notify your customers within 30 days using the enclosed instructions and public notice.
2. Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
3. Perform quarterly monitoring for HAA5 during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
4. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any existing enforcement action that has been issued to you.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Sarah Byerly,
Compliance Assurance Section
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form
cc: Manager; DDAGW file; NWDO file; Henry County Health Department