

RECEIVED



JUN 12 2007 KB

State of Ohio Environment

OH3500912

LHS MAUMEE YOUTH CENTER

2950

02 06/07/07

**STREET ADDRESS:**

Lazarus Government Center  
50 W Town Street, Suite 700  
Columbus, OH 43215

TELE: (614) 644-3020



June 07, 2007

Re: Henry County  
LHS Maumee Youth Center  
Nontransient Noncommunity Water System  
PWS ID: OH3500912

CERTIFIED MAIL

91 7108 2133 3931 0973 8374

LUTHERAN HOMES FAMILY & YOUTH SERVICES  
2411 SEAMAN ST  
TOLEDO, OH 43605

**RE: TRIHALOMETHANES, TOTAL (TTHM) MAXIMUM CONTAMINANT LEVEL EXCEEDANCE**

Dear Public Water System Owner:

This letter is notification that your public water system is in violation of rule 3745-81-12 of the Ohio Administrative Code (OAC). LHS Maumee Youth Center has exceeded the maximum contaminant level (MCL) for TTHM within the January 1 through March 31, 2007 time period.

Paragraph B of rule 3745-81-12 establishes an MCL of 0.080 milligrams per liter (mg/L) for TTHM. Compliance with the MCL is based on the running annual average of four consecutive quarters of samples. The current running annual average for TTHM is 0.081 mg/L.

As a result of this violation, rule 3745-81-32 of the OAC requires that a public notice be issued by your facility informing your consumers of the violation. Included with this violation is a public notice containing the mandatory health effects language that must appear in the notice. If you wish to make additional statements in the notice, this office must be contacted first. The public notice must be issued within 30 days as specified in the enclosed "Public Notice Instructions and Verification Form for Community Public Water Systems with Tier 2 Violations". Please complete and return this form along with a copy of the public notice, once it is issued.

LHS Maumee Youth Center public water system is required to continue monitoring according to your most recent Chemical Monitoring Distribution Schedule. For questions concerning the public notice requirement, please contact me at (614) 644-2752.

Sincerely,

Kenneth Baughman  
Compliance Assurance Section  
Division of Drinking and Ground Waters

Enclosures: Public Notice and Verification Form for Tier 2 Violations

cc: Superintendent/Manager; NWDO, DDAGW; DDAGW; Henry County Health Department

