



Environmental  
Protection Agency

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director

F

July 16, 2010

RE: HINCKLEY TOWN HALL/ FIRE DEPT.  
PERMIT NO. 3PR00500\*AD  
MEDINA COUNTY  
HINCKLEY TOWNSHIP

Mr. Paul Magovac, Foreman  
Hinckley Service Dept.  
1616 Ridge Rd.  
Hinckley, Ohio 44233

Dear Mr. Magovac:

On July 15, 2010, an inspection of the above referenced facility's wastewater treatment system was conducted. No one was present during the inspection. The purpose of the inspection was to evaluate the operation and maintenance of the treatment system along with the facility's compliance status with respect to the terms and conditions of the above referenced National Pollutant Discharge Elimination System (NPDES) permit.

During the inspection, the following items were noted:

1. The treatment system was not able to be properly evaluated because the treatment system tank grates were covered with screening and were locked.
2. The surface sand filter beds were severely overgrown with vegetation. See Figure 1. The beds should be maintained free of vegetation. Any vegetation and solids deposition on the surface sand filter beds should be properly disposed at a licensed solid waste landfill.

This office has recently reviewed your self-monitoring reports covering the period September 1, 2009 through June 30, 2010 for the referenced facility. Our review indicates there were no violations of the terms and conditions of your NPDES permit.

The facility has been reporting code "AL" each month which indicates that no discharge has occurred from the treatment system during the monitoring period.

**Please notify this office within 14 days receipt of this letter your intentions to resolve item 2. A follow-up inspection will be conducted subsequent to the completion date.**

Please be advised that such instances of non-compliance may be cause for enforcement actions pursuant to the Ohio Revised Code, Chapter 6111.

Should you have any comments or questions concerning this letter, please feel free to call me at (330) 963-1143.

Respectfully,

Michael W. Stevens  
Environmental Engineer  
Division of Surface Water

MWS/mt



Figure 1