



**Environmental
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

F

October 26, 2011

RE: HOLMES COUNTY
VILLAGE OF MILLERSBURG
MIDWEST COMMUNITY SERVICES – HOME 1
OHIO EPA PERMIT NO. 3PR00429*BD

Ms. Tracy Hartman, Manager
ANMAC Home IV
Leeda Services, Inc.
5650 Township Road 332
Millersburg, OH 44654

Dear Ms. Hartman:

On October 19, 2011, a site inspection was conducted at the above referenced facility at 5650 Township Road 332, Village of Millersburg, Holmes County. During the inspection, I was accompanied by Dean Stoll of Ohio EPA and Kraig Bucklew of the Holmes County Health Department. The purpose of the inspection was to evaluate the facility's compliance status with respect to the terms and conditions of the facility's National Pollutant Discharge Elimination System (NPDES) permit.

The 1,500 gallons per day extended aeration plant (treatment works) consists of a trash trap, extended aeration system with clarifier, lift station/dosing chamber, surface sand filtration, chlorine disinfection, and dechlorination. Sludge management consists of sludge removal when needed to another treatment works. The treatment works discharges to an unnamed tributary to Killbuck Creek.

Observations

The following observations were made during the inspection:

1. The contents of the aeration tank had no odor and were a chocolate brown color with good mixing. The blowers were running and the plant was receiving sufficient aeration. The plant color and aeration is an indicator of a properly operating aeration system.
2. The blowers were running and the treatment works was receiving sufficient aeration and good mixing.
3. The surface of the clarifier was clear. Effluent channels and weirs were also clear.
4. The surface sand filters need to be cleaned as there were excessive leaves and ponded wastewater observed (Figure 1).
5. Chlorination and dechlorination systems were stocked with appropriate chemicals.

NPDES Permit Compliance Review

A review of the electronic discharge self-monitoring reports (eDMR) received by Ohio EPA for the period September 1, 2010, through October 1, 2011, indicates that no violations have occurred.

TRACY HARTMAN
MIDWEST COMMUNITY SERVICES – HOME 1
OCTOBER 26, 2011
PAGE 2 OF 2

the period September 1, 2010, through October 1, 2011, indicates that no violations have occurred.

Should you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1118 or via e-mail at chris.moody@epa.ohio.gov.

Sincerely,



Chris Moody.
Environmental Specialist II
Division of Surface Water

cc: Kraig Bucklew, Holmes County Health Department



Figure 1 - The surface sand filters need to be cleaned as there were excessive leaves and ponded wastewater observed.