





**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Putnam County  
Country Acres Golf Club PWS  
Community Public Water System  
PWS ID# 6901412

January 13, 2012

Mr. Ron Klausing, President  
Country Acres Golf Club  
17374 State Route 694  
Ottawa, Ohio 45875

**Notice of Violation – Monthly Report – Chlorine Residual Distribution**

Dear Mr. Klausing:

Notice of Violation

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the distribution system December 1, 2, 7, 8, 9, 10, 11, 12, 13, 14, 15, 19, 20, 21, 22, 23, 24, 25, 28, 30 and 31.

OAC Rule 3745-83-01 (C) (1) requires all community public water systems to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3007 or via e-mail to [clayton.mckee@epa.state.oh.us](mailto:clayton.mckee@epa.state.oh.us).

Sincerely,

Clayton McKee  
Environmental Specialist 2  
Division of Drinking and Ground Waters

//lr

pc: Jim Hemrick  
Putnam County Health Department  
NWDO – DDAGW

ec: Linda Benham, OEPA, NWDO  
Ellen Gerber, OEPA, NWDO

