



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Sandusky County
Hidden Hills Golf Club Inc
TNC Water System
PWS ID #OH7235112

April 19, 2011

Mr. Mickey Pierce
Hidden Hills Golf Club, Inc.
4886 County Road 16
Woodville, Ohio 43469

Dear Mr. Pierce:

This letter will confirm removal of the water use advisory required in our letter dated April 7, 2011. This is based on one set of four total coliform negative (safe) samples collected April 5, 2011, and received by our office on April 12, 2011.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, OH 43402 by May 2, 2011.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of April 2011.

Yours truly,



Kimberly K. Burnham, R.S.
Division of Drinking and Ground Waters

/llr

pc: Sandusky County Health Department
Data Management Section, DDAGW, CO, Attn: Toni Buchanan
DDAGW, NWDO File

(

(

1998

10

1998

1998

1998

1998

10

10

10