





State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.ohio.gov

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

Re: Sandusky County  
Hidden Hills Golf Club, Inc.  
TNC Water System  
PWS ID # OH7235112

April 2, 2010

Mr. Mickey Pierce  
Hidden Hills Golf Club, Inc.  
4886 County Road 16  
Woodville, Ohio 43469

Dear Mr. Pierce:

This letter will confirm removal of the water use advisory required in our letter dated March 1, 2010. This is based on one set of four total coliform negative (safe) samples collected March 24, 2010.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, OH 43402 by April 16, 2010.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five routine samples during the month of April 2010.

Yours truly,

JoAnn Sabo  
Division of Drinking and Ground Waters

JKS/lb

pc: Sandusky County Health Department  
Data Management Section, DDAGW, CO, Attn: Toni Buchanan  
DDAGW, NWDO

(

(

1998-1999