





**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Henry County
Village of Florida
Community Public Water System
PWS ID# OH 3501203
STU ID# 3554991

January 12 2012

Mr. Bruce Meyer, President
Board of Public Affairs
206 East High Street
Napoleon, Ohio 43545

Dear Mr. Meyer:

On January 4, 2012, the Ohio Environmental Protection Agency (Ohio EPA), Division of Drinking and Ground Waters (DDAGW), received a letter from Kip Labie in response to Ohio EPA's November 23, 2011, report regarding the November 9, 2011, sanitary survey of the Village of Florida public water system. Ohio EPA has reviewed the letter and has the following comments.

COMMENTS

1. Item 1 requires the development of a Total Coliform Sample Siting Plan. Per the provided response, a copy of the plan shall be provided to this office by April 30, 2012.
2. Item 2 requires the development of a Contingency Plan. Per the provided response, a copy of the cover page and table of contents shall be provided to this office by April 30, 2012.
3. Item 3 requires the development of a Disinfection By-Products Sample Siting Plan. Per the provided response, a copy of the plan shall be provided to this office by April 30, 2012.
4. Item 4 required the removal of the yard hydrants with weep holes. Per the January 4, 2012 response, this has been completed at this time.

Thank you for your prompt action in regards to these matters.

Mr. Bruce Meyer, President
January 12, 2012
Page 2

If you have any questions regarding this letter, or any other matter involving your water system, please contact me at 419-373-3101 or via email at Chris.Riddle@epa.state.oh.us.

Sincerely,



Chris Riddle
Environmental Specialist 2
Division of Drinking and Ground Waters

//lr

pc: Kip Laibe, Operator with enclosures
Henry County Health Department
Dave Bornino, DDAGW, Operations CO - with enclosures
DDAGW - NWDO File with enclosures