



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Henry County
Malinta Village
Community Public Water System
PWS ID# OH 3501403
STU ID# 3554992

January 12, 2012

The Honorable Ruth Medina
Mayor of the Village of Malinta
103 ½ Turkeyfoot Street
P. O. Box 60
Malinta, Ohio 43535

Dear Mayor Medina:

On January 4, 2012, the Ohio Environmental Protection Agency (Ohio EPA), Division of Drinking and Ground Waters (DDAGW), received a letter from Kip Labie in response to Ohio EPA's November 28, 2011, report regarding the November 9, 2011, sanitary survey of the Village of Malinta public water system. Ohio EPA has reviewed the letter and has the following comments.

COMMENTS


1. The Total Coliform Sample Siting Plan required in Item 1 has been completed and a copy has been provided to this office. No further action is necessary for this item.
2. Item 2 requires the development of a Contingency Plan. Per the provided response, a copy of the cover page and table of contents shall be provided to this office by April 30, 2012.
3. Item 3 requires the development of a Disinfection By-Products Sample Siting Plan. Per the provided response, a copy of the plan shall be provided to this office by April 30, 2012.
4. Item 4 required additional work necessary to implement a proper backflow prevention and cross connection control program. Implementation of this program is an ongoing requirement and progress towards completing these tasks and tracking the work completed will be evaluated as a part of the next sanitary survey.

The Honorable Ruth Medina
January 12, 2012
Page 2

Thank you for your prompt action in regards to these matters.

If you have any questions regarding this letter, or any other matter involving your water system, please contact me at 419-373-3101 or via email at Chris.Riddle@epa.state.oh.us.

Sincerely,



Chris Riddle
Environmental Specialist 2
Division of Drinking and Ground Waters

/llr

pc: Kip Laibe, Operator with enclosures
Henry County Health Department
Dave Bornino, DDAGW, Operations CO - with enclosures
DDAGW - NWDO File with enclosures