





Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Ottawa County
Allen Park Mobile Court
Community Public Water System
PWS ID# OH6204112
STU ID# 62546919

November 29, 2011

Mr. Dennis B. Brophy
Pacific NW Property Management
15685 SW 116th Street, #109
King City, Oregon 97224-2695

Notice of Violation – Monthly Report

Dear Mr. Brophy:

The Division of Drinking and Ground Waters (DDAGW) Plant – Distribution Monthly Operating Report (MOR) for the month of October 2011, was received by the Ohio EPA- Northwest District Office (NWDO) as required on November 4, 2011.

Review of the October 2011 MOR indicates that the analytical result (0.350 mg/L) for iron exceeds the secondary maximum contaminant level (MCL). The Ohio Administrative Code (OAC) rule 3745-82-02 establishes the secondary MCL at (0.3 mg/L) for iron. OAC rule 3745-91-09 requires provision of treatment for removal of iron when an excessive amount of this substance is present in the untreated water. Consider the following items to determine why the standard is not being met:

1. Review the sampling location and technique used (i.e. was the sample pulled too soon after backwash events?)
2. Review the operation/maintenance of the filtering units (i.e. what is the head loss across the whole unit, is the filter media cemented or is channeling of the media occurring?)
3. Provide additional units/new equipment, or change treatment sequence. *

** Note: Plan approval by this agency is required whenever a substantial change is made to the water system.*

Additionally, the Chlorine Residual (Total) box located near the top of page 2 was not completed as required. This box replaced the former Total Chlorine Quarterly Report form EPA 5114.

Mr. Dennis B. Brophy
November 29, 2011
Page 2

If you have any questions regarding this letter, or any other matter involving your PWS, then contact me directly by telephone at (419) 373-3088 or via electronic messaging at jack.schwartz@epa.state.oh.us.

Sincerely,



John A. (Jack) Schwartz
Environmental Specialist 2
Public Drinking Water Unit
Division of Drinking and Ground Waters

JAS/lir

pc: Lorell Anderson, Park Manager
Zach Danzer, Maintenance Manager
Joseph L. St. Clair, Operator
Ottawa County Health Department
DDAGW, NWDO Correspondence File

ec: Linda S. Benham, Environmental Supervisor, DDAGW, NWDO
Justin Bowerman, DOCC, DDAGW, NWDO