





Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Putnam County
Country Acres Golf Club PWS
Community Public Water System
PWS ID# 6901412

November 23, 2011

Mr. Ron Klausing, President
Country Acres Golf Club
17374 State Route 694
Ottawa, Ohio 45875

**Notice of Violation – Monthly Report – Chlorine Residual Distribution
Notice of Deficiency – Monthly Report – Chlorine Residuals – Plant Tap**

Dear Mr. Klausing:

Notice of Violation

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the distribution system October 1, 2, 3, 5, 6, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 20, 21, 22, 23, 24, 26, 29, 30, and 31

OAC Rule 3745-83-01 (C) (1) requires all community public water systems to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to Chris.Riddle@epa.state.oh.us.

Sincerely,

Chris Riddle
Environmental Specialist 2
Division of Drinking and Ground Waters

/l/r

pc: Jim Hemrick, Country Acres Golf Club
Putnam County Health Department

NWDO – DDAGW

ec: Linda Benham, OEPA, NWDO
Ellen Gerber, OEPA, NWDO

