





Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Paulding County  
Community PWS  
Village of Oakwood  
PWS ID# OH 6300312  
STU ID# 6357098

November 28, 2011

Mr. John Keyes  
Village of Oakwood  
228 North First Street  
Oakwood, Ohio 45873

**Violation of the secondary standard for manganese - NOV OAC 3745-82-02**

Dear Mr. Keyes:

Notice of Violation

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for manganese which is 0.05 mg/L. There were three (3) weeks during the month of October 2011, in which manganese exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for manganese are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01 (F)(6) to determine compliance with the secondary maximum contaminant level for manganese.
- (b) A public water system shall be in violation of the secondary standard for manganese when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for manganese does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to [Chris.Riddle@epa.state.oh.us](mailto:Chris.Riddle@epa.state.oh.us).

Sincerely,

Chris Riddle  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/llr

pc: Paulding County Health Department  
DDAGW-NWDO File

Northwest District Office  
347 North Dunbridge Road  
Bowling Green, OH 43402-9398

419 | 352 8461  
419 | 352 8468 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)

