





**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Allen County  
Indian Village Mobile Home Park  
Community PWS  
PWS ID# 0200712

January 13, 2012

Mr. Trace Meyer, General Manager  
Park Management Specialties  
216 West Wayne Street  
Maumee, Ohio 43537

**Notice of Violation – Monthly Report – Secondary Standard for Iron**

Dear Mr. Meyer:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for iron which is 0.3 mg/L. There were four (4) weeks during the month in which iron exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for iron are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01 (F)(5) to determine compliance with the secondary maximum contaminant level for iron.
- (b) A public water system shall be in violation of the secondary standard for iron when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for iron does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

Failure to take action to address this violation may result in enforcement action being taken.

Mr. Trace Meyer, General Manager  
January 13, 2012  
Page 2

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3007 or via e-mail to [clayton.mckee@epa.state.oh.us](mailto:clayton.mckee@epa.state.oh.us).

Sincerely,



Clayton McKee  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/llr

pc: Allen County Health Department  
NWDO - DDAGW File

ec: Linda Benham, OEPA, NWDO  
Ellen Gerber, OEPA, NWDO