



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Allen County  
LaFayette Congregational Christian Church  
TNC Public Water System  
PWS ID# OH0233312  
STU ID# 252650

December 5, 2011

Mr. Jerry Maus, Moderator  
LaFayette Congregational Christian Church  
201 West Main Street  
P. O. Box 7242  
Lafayette, Ohio 45854

**Subject: Notice of Violation for Failure to Respond to a Significant Deficiency**

This letter is notification that the LaFayette Congregational Christian Church has not complied with requirements issued during this Agency's last survey performed on September 28, 2011, and therefore is in violation of rule 3745-81-60 of the Ohio Administrative Code. The church was notified in correspondence dated October 18, 2011, to respond in writing no later than 30 days, with time frames for:

- OAC Rule 3745-91-02(A) states, "No person shall begin construction or installation of a public water system, or make a substantial change in a public water system, until plans therefor have been approved by the director of environmental protection. An application for approval of plans for such construction, installation, or substantial change in a public water system, as required by section 6109.07 of the Revised Code, shall be submitted to the district office..."


A peroxide feed system was present during the survey and does not appear in the plan approval dated March 2, 2007, from the director of the Ohio EPA. Contact Paul Brock, Engineer of our office at 419-373-3152 regarding the discrepancy.

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

Mr. Jerry Maus, Moderator  
December 5, 2011  
Page 2

If you have any questions, please contact me at 419-373-3089 or via email at [jill.schiefer@epa.state.oh.us](mailto:jill.schiefer@epa.state.oh.us) .

Sincerely,



Jill A. Schiefer  
Environmental Specialist  
Division of Drinking and Ground Waters

/lir

pc: Allen County Health Department  
Dave Bornino, CO - DDAGW/OFAS  
DDAGW - NWDO File

ec: Paul Brock, Engineer, NWDO-DDAGW  
Linda Benham, Supervisor, NWDO-DDAGW