





Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Auglaize County  
ODOT Rest Area 7-26 PWS  
TNC Public Water System  
PWS ID# 0632412

November 23, 2011

Mr. Lonnie Falknor  
1001 St. Marys Avenue  
P. O. Box 969  
Sidney, Ohio 45365

**Notice of Violation – Monthly Report – Chlorine Residual Distribution**

Dear Mr. Falknor:

Notice of Violation

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l ) and combined chlorine residual of less than one mg/l in the distribution system October 1, 2, 10, 11, 12, 13, & 29.

OAC Rule 3745-83-01 (C) (1) requires all noncommunity public water systems serving at least 1,000 people to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

Notice of Deficiency

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l ) and combined chlorine residual of less than one mg/l on October 1, 2, 10, & 11.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to [Chris.Riddle@epa.state.oh.us](mailto:Chris.Riddle@epa.state.oh.us).

Sincerely,

Chris Riddle  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/llr

pc: Auglaize County Health Department  
DDAGW-NWDO File

