





**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Fulton County
ODNR--Harrison Lake State Park
TNC Water System
PWS ID # OH2631412

January 5, 2012

Ms. Melissa Taylor
ODNR-Harrison Lake State Park
2045 Morse Road C-3
Columbus, Ohio 43229

Dear Ms. Taylor:

This letter will confirm removal of the water use advisory required in our letter dated January 4, 2012. This is based on one set of four total coliform negative (safe) samples being collected.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, OH 43402 by January 18, 2012.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of January 2012.

Yours truly,

Jill A. Schiefer
Division of Drinking and Ground Waters

//lr

pc: James O'Brien, Park Manager
Fulton County Health Department
IMS, DDAGW, CO, Attn: Toni Buchanan
DDAGW, NWDO

