





**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Fulton County  
Mennonite Church of the Good Shepherd  
TNC Water System  
PWS ID # OH2637012

December 13, 2011

Mr. Joe Huerta  
Mennonite Church of the Good Shepherd  
22489 County Road F  
Archbold, Ohio 43502

Dear Mr. Huerta:

This letter will confirm removal of the water use advisory required in our letter dated November 29, 2011. This is based on one set of four total coliform negative (safe) samples collected on November 15, 2011, and received by our office on December 1, 2011.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, OH 43402 by December 23, 2011.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of December 2011.

Yours truly,

Jill A. Schiefer  
Division of Drinking and Ground Waters

/llr

pc: Fulton County Health Department  
IMS, DDAGW, CO, Attn: Toni Buchanan  
DDAGW, NWDO

