





**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Hardin County  
Hi-Road Drive-In Theatre  
TNC Water System  
PWS ID # OH3331312

January 3, 2012

Mr. Rodney Miller  
Hi-Road Drive-In Theater  
106 West Pike Street  
P. O. Box 477  
Jackson Center, Ohio 45334

Dear Mr. Miller:

This letter will confirm removal of the water use advisory required in our letter dated October 20, 2011. This is based on one set of four total coliform negative (safe) samples collected October 17, 2011, and received by our office on October 20, 2011.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five routine samples prior to opening for the 2012 operating season.

Yours truly,

John A. (Jack) Schwartz  
Division of Drinking and Ground Waters

/l/r

pc: Hardin County Health Department  
IMS, DDAGW, CO, Attn: Toni Buchanan  
DDAGW, NWDO

