



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Seneca County
TNC Water System
Steyer AMLC #1
PWS ID# OH7442212
STU ID# 7458151

November 22, 2011

CERTIFIED MAIL

Mr. Tony Steyer
Steyer AMLC No. 1-FC
5739 North County Road 33
Tiffin, Ohio 44883

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

This letter is notification that the Steyer AMLC #1 has not complied with requirements issued during this Agency's last survey performed on October 4, 2011, in violation of rule 3745-81-60 of the Ohio Administrative Code. **The PWS was notified in correspondence dated October 18, 2011, to respond in writing no later than 30 days, with time frames for:**


1. A total coliform sample siting plan was not on file. A template for a total coliform sample siting plan was given to you on the day of the survey. The template for the plan should be completed and filed. The plan should be maintained and updated as required. [OAC 3745-81-21(A)]
2. Yard hydrants with weep holes are prohibited. Remove all yard hydrants, remove the weep hole, or replace them with sanitary yard hydrants that do not have a weep holes, such as those that meet the requirements of the "American Society of Sanitary Engineers (ASSE) standard 1057, Performance Requirements for Freeze Resistant Yard Hydrants with Backflow Protection"(2001). [OAC Rule 3745-95-09(A)]
3. The electrical conduit connection on the well cap is cracked and is not threaded. The connection on the well cap must be repaired or replaced and must be threaded and sealed to prevent the entrance of insects and water. [OAC Rule 3745-9-05(P)]

Mr. Tony Steyer
November 22, 2011
Page 2

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions regarding this letter, or any other matter involving your water system, contact Beth Ames at 419-373-3107 or via email at Elizabeth.Ames@epa.state.oh.us.

Sincerely,



Janis D'Amico
Environmental Specialist 2
Division of Drinking and Ground Waters

/l/r

cc: Gene Phillips, Ohio Department of Health
OEPA Central Office, DDAGW
DDAGW, NWDO File
Certified Receipt Number 7009 1410 0001 1834 1903

ec: Linda Benham, DDAGW, NWDO