





**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Ottawa County
TNC Public Water System
Hasselkus AMLC
PWS ID# OH6234112
STU ID# 6256953

December 14, 2011

CERTIFIED MAIL

Mr. Mark Hasselkus
Hasselkus AMLC
2673 South Hessville Road
Elmore, Ohio 43416

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

This letter is notification that Hasselkus AMLC has not complied with requirements issued during this Agency's last survey performed on June 7, 2011, in violation of rule 3745-81-60 of the Ohio Administrative Code. The village was notified in correspondence dated June 16, 2011, to respond in writing no later than 30 days, with time frames for:

1. The well cap and electrical conduit connection on the cap are not sealed. Electrical conduit connections on the well cap must be threaded and sealed to prevent the entrance of insects and water. Replace the well cap with one that has a watertight connection with the casing and electrical conduit. [OAC Rule 3745-9-05(P)]
2. A vent shall be provided on all well caps and seals. Install a cap with a vent that is self-draining, screened with a non-corroding mesh screen of fifteen to thirty mesh, and pointed downward at or above the top of the casing or pitless unit. The vent shall terminate not less than twelve inches above ground surface. [OAC 3745-9-05 (T)]

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

Mr. Mark Hasselkus
December 14, 2011
Page 2

If you have any questions, please contact me at 419-373-3107.

Sincerely,



Elizabeth Ames
Environmental Specialist 2
Division of Drinking and Ground Waters

/lr

pc: Ottawa County Health Department
Central Office, DDAGW
Certified Mail Receipt Number 7009 1410 0001.1834 1835