





**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Sandusky County
Hidden Hills Golf Club, LLC
TNC Water System
PWS ID #OH7235112

December 22, 2011

Ms. Kathy Fox
Hidden Hills Golf Club, LLC
4900 County Road 16
Woodville, Ohio 43469

Dear Ms. Fox:

This letter will confirm removal of the water use advisory required in our letter dated December 22, 2011. This is based on one set of four total coliform negative (safe) repeat samples being collected.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, OH 43402 by January 5, 2012.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of December 2011.

Yours truly,



Kimberly K. Burnham, R.S.
Division of Drinking and Ground Waters

JKS/cs *

pc: Roberta Orians (same address)
Sandusky County Health Department
IMS, DDAGW, CO, Attn: Toni Buchanan
DDAGW, NWDO File

