



State of Ohio Environmental Protection Agency

STREET ADDRESS:

OH3833212 HOLMES LUMBER AND BUILDING 2964 02 09/22/09

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-2751
www.epa.gov



* 0 H 3 8 3 3 2 1 2 9 6 8 2 4 1 1 *

NOTICE OF VIOLATION – ACTION REQUIRED

September 22, 2009

CERTIFIED MAIL

Holmes Lumber and Building Center
Holmes Lumber and Building
6139 State Route 39,
Millersburg, OH 44654

Holmes County
Holmes Lumber and Building
Non Transient Non Community PWS
PWS ID: OH3833212
Facility ID: 3855143

Subject: Violation of Maximum Contaminant Level for DICHLOROMETHANE

Holmes Lumber and Building is in violation for exceeding the maximum contaminant level (MCL) standard of 0.005 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-12 for DICHLOROMETHANE. Compliance with the MCL is based on a running annual average. The annual average for DICHLOROMETHANE during the First Quarter of 2009 time period is 0.014 MG/L.

To address the MCL violation, Holmes Lumber and Building is required to take the following actions:

- Notify your customers within 30 days using the enclosed instructions and public notice.
- Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
- Perform quarterly monitoring for DICHLOROMETHANE during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
- Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any existing enforcement action that has been issued to you.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Sarah Byerly
Division of Drinking and Ground Waters

Enclosure: Public Notice, Verification Form

cc: DDAGW NEDO; DDAGW CO file

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director