



Environmental
Protection Agency

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Koreski, Director

OH3901612 IRBW PROPERTIES, LTD. DBA W 2950 02 11/18/10



November 18, 2010

CERTIFIED MAIL

NOTICE OF VIOLATION – ACTION REQUIRED

Julie Vantaggi
IRBW Properties, Ltd. DBA Willard MHP
6 Corporation Center,
Broadview Heights, OH 44147

Huron County
IRBW Properties, Ltd. DBA Willard MHP
Community PWS
PWS ID: OH3901612

Subject: Violation of Maximum Contaminant Level for TOTAL TRIHALOMETHANES (TTHM)

Willard MHP is in violation for exceeding the maximum contaminant level (MCL) standard of 0.080 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-12 for TTHM. Compliance with the MCL is based on a running annual average. The annual average for TTHM during the Third Quarter of 2010 time period is 0.081 MG/L.

To address the MCL violation, Willard MHP is required to take the following actions:

1. Notify your customers within 30 days using the enclosed instructions and public notice.
2. Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
3. Perform quarterly monitoring for TTHM during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
4. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any existing enforcement action that has been issued to you.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Sarah Byerly
Compliance Assurance Section
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form
cc: Manager; DDAGW file; NWDO file; Huron County Health Department