



Environmental
Protection Agency

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

OH4644122 NEX TRANSPORT-SOUTH

CDBP 27 12/01/10



December 1, 2010

NOTICE OF VIOLATION – ACTION REQUIRED

Fred Lafrance
Nex Transport-South
13900 St Rt 287,
East Liberty, OH 43319

Logan County
Nex Transport-South PWS
NONTRANSIENT NONCOMMUNITY
PWS ID: OH4644122

Subject: Failure to Monitor Drinking Water

Nex Transport-South is in violation of Ohio Administrative Code Rule (OAC) 3745-81-24 for failing to monitor your drinking water during the Three Year (2008-2010) monitoring period and/or report results for the following contaminants: TOTAL TRIHALOMETHANES (TTHM), HALOACETIC ACIDS, FIVE (HAA5).

In order to return to compliance, Nex Transport-South must take the following actions:

1. Immediately collect a sample of your drinking water from the maximum residence time (location in the systems where the age of the water is the oldest).
2. Submit the sample for analysis to a certified laboratory on the enclosed list.
3. Notify your customers using the enclosed instructions and public notice.
4. Complete and return the enclosed verification form to this office.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions, or if the required sample analysis was performed, please call me at (614) 644-2752.

Sincerely,

Sarah Byerly

Division of Drinking and Ground Waters

Enclosure: Laboratory List, Public Notice, Verification Form

cc: Manager; DDAGW SWDO file; DDAGW CO file