



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

December 28, 2007

**Re: Fairfield County
Buckeye Beach Marina MHP
Community PWS
PWS ID #2302212**

Mr Fred Bair
Buckeye Beach Marina MHP
7658 Slate Ridge Boulevard
Reynoldsburg, OH 42068

**Subject: Notice of Violation - Failure to Sample Drinking Water as Required for
Total Coliforms**

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

Monitoring Period:	November 2007
Required Coliform Sampling:	At least 1 sample(s) each month.
Sample Results Submitted:	NONE

Actions required as a result of the above violation


Step 1	<p>Within 30 days issue public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following methods:</p> <ol style="list-style-type: none"> 1. mail or other direct delivery to each customer receiving a bill and to other service connections; and 2. if necessary, the system must also use any other method reasonably calculated to reach all persons. <p>Note: Systems opting to include the required public notice in the next water bill have up to 90 days.</p> <p>The language in italic on the attached public notice is mandatory and must be included as written.</p>
Step 2	<p>Within ten (10) days of completing Step 1 above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of Ohio EPA.</p>

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

Mr Fred Bair
Buckeye Beach Marina MHP
Page -2-

If you have any questions, please contact me at (614) 728-3870.

Sincerely,

A handwritten signature in cursive script, appearing to read "Bridgette Marchio".

Bridgette Marchio
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures

c: Fairfield County Health Department
Toni Buchanan, DDAGW/CO
CDO File