



State of Ohio Environmental Protection Agency

## STREET ADDRESS:

**Central District Office**

## MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.usP.O. Box 1049  
Columbus, OH 43216-1049

September 10, 2010

**Re: Fairfield County  
Hillview Mobile Village  
Community PWS  
PWS ID #OH2302712**Hillview Mobile Village  
15111 State Route 664 South  
Logan, OH 43138**Subject: Notice of Violation - Failure to Submit Operational Reports**

A review of our records indicates that the operational reports for Hillview Mobile Village public water system have not been submitted for July 2010. This failure to submit reports constitutes a violation of the Ohio Administrative Code, Rule 3745-81-31 and Section 6109.12 of the Ohio Revised Code.

Reports required to be completed and submitted to Ohio EPA include:

1. Plant-Distribution Monthly Operation Report, EPA form 5002

The required reports must be completed and submitted to this office by the tenth of the month following the reporting period. All required reports for the reporting period July 2010 must be forwarded to my attention within 15 days.

If you have any questions, please contact me at (614) 728-3874.

Sincerely,

Raymond Shesky  
Environmental Specialist II  
Division of Drinking and Ground Waters  
Central District Office

Enclosures

c: Fairfield County Health Department  
Toni Buchanan, DDAGW/CO  
CDO File

RS/ct 2302712\_Jul10\_MOR

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

