



State of Ohio Environmental Protection Agency



## STREET ADDRESS:

Central District Office

## MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

November 17, 2008

Re: **Fayette County**  
**I-71 And SR-35 Water System**  
**Community PWS**  
**PWS ID #OH2437412**

I-71 And SR-35 Water System  
133 S. Main Street  
Suite 401  
Washington Court House, OH 43160

**Subject: Failure to Sample Drinking Water as Required for Lead and Copper**

Your public water system failed to collect lead and copper samples as follows:

Monitoring Period:	June 1 - September 30, 2008
Required Sampling:	10 samples for each lead and copper
Sample Results Submitted:	None

**Actions required as a result of the above**

Collect and analyze the required number of lead and copper tap samples during June 1 - September 30, 2009. Based upon the reported population, you are required to collect a minimum of 10 lead and copper samples. Report results on the enclosed forms 5105, 5106 and 5107 by October 10, 2009.

Sampling in 2009 is needed to return your system to compliance as a result of a failure to collect lead and copper samples in a prior year. **Note that this will not be listed on your 2009 monitoring schedule.** If you have any questions, please contact me at (614) 728-3870.

Sincerely,

  
Bridgette Marchio  
Environmental Specialist II  
Division of Drinking and Ground Waters  
Central District Office

Enclosures

c: Fayette County Health Department  
CDO File

BM/ct OH2437412 lead mon via June Sept 2008

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director