

**SIGNATURE RECEIVED**

3/2/09

OH2400612

VILLAGE OF JEFFERSONVILLE

2/25/2009



State of Ohio Environmental Protection Agency

STREET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

**CERTIFIED MAIL 91 7108 2133 3932 4450 0157**

February 25, 2009

**Re: Fayette County  
Village of Jeffersonville  
Community Water System  
PWS ID: 2400612  
STU ID: 2454044**

Mr. Johnnie Bobbitt  
BOPA President  
Village of Jeffersonville  
4 North Main Street  
P.O. Box 7  
Jeffersonville, OH 43128

**Subject: Notice of Violation for Failure to Respond to a Significant Deficiency**

Dear Mr. Bobbitt:

This letter is notification that the Village of Jeffersonville has not complied with requirements issued during this Agency's last survey performed on October 30, 2008, in violation of rule 3745-81-60 of the Ohio Administrative Code. The Village was notified in correspondence dated December 10, 2008, to respond in writing no later than 45 days, with time frames for:

1. Sealing of the Short Woods well and submitting a copy of the well sealing report to Ohio EPA.
2. Providing a course of action to reduce or eliminate the standing water in the valve pits of the wells.
3. Repairing the electrical conduit on the Jeff well.
4. Removing the large horse manure pile within 100 feet of the Spahr well.
5. Grading the ground surrounding the Roll well to promote drainage away from the wellhead.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Ohio EPA is an Equal Opportunity Employer

Mr. Johnnie Bobbitt  
Village of Jeffersonville  
Page -2-

6. Making all the required improvements to the chlorine feed system.
7. Filling in and grading the ground that was excavated near the water treatment building to move the pig farm fence line.
8. Removing the debris from the overflow pipe on the High Street tower.
9. Incorporating in future capital improvement plans the upgrading of water mains that serve the twelve (12) hydrants throughout the distribution system that are located on less than 6 inch diameter water mains.
10. Providing an adequate air gap between the filter backwash discharge line and the rim of the waste trough.
11. Updating your current contingency plan to address all the requirements as outlined in the survey letter.
12. Maintaining operations and maintenance records for the public water system in accordance with OAC 3745-7-09.

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions, please contact me at (614) 728-3870.

Sincerely,



Bridgette Marchio  
Environmental Specialist  
Division of Drinking and Ground Waters  
Central District Office

c: Fayette County Health Department  
Charles Bauer, Jeffersonville Water Superintendent  
C.O. - DDAGW / OFAS  
CDO File