




Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



* 0 H 2 5 0 0 5 1 2 1 0 6 2 0 1 1 N O V *

October 6, 2011

Re: Franklin County
Community Gardens MHP
Community PWS
PWS ID #2500512

Sandy McCoy
Community Gardens MHP
6244 London-Groveport Road
Grove City, OH 43123

Violation – Failure to Sample Raw Water for Total Coliform Bacteria

Your public water system is in violation of Rule 3745-81-76(b)(2)(b) and 3745-83-01(H) of the Ohio Administrative Code for failure to comply with the following raw water bacteria monitoring requirements:

<i>Type 34</i>	Period:	September 2011
	Sampling:	Well #1 – Monthly
	Submitted:	0
as a result of the above violation		
Total coliform bacteria sample monthly from Well #1 beginning		

Additionally, you have failed to respond to the items listed in the August 31, 2011 letter (attached). Please prepare a response and submit it to my attention within 14 days of the date of this letter. Attached is a copy of the letter.

If you have any questions, please contact me at (614) 728-3864.

Sincerely,

Carolyn O'Neal
Environmental Specialist III
Division of Drinking and Ground Waters
Central District Office

Enclosure: August 31, 2011 Letter

c: Franklin County Health Department
Suzanne Matz w/ enclosure)
Louis DeVault w/ enclosure)
John Kinder, Kinder Environmental Services, Inc. w/ enclosure
CDO File

CO/ct 2500512(CommGarRawTCMonVioSept11

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

