



State of Ohio Environment



Central District Office

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3776 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

April 2, 2007

Re: Franklin County
Sanitary District #4
Community PWS
PWS ID #: 2501003

Franklin County Sanitary Engineer
Sanitary District #4
280 East Broad Street, Room 201
Columbus, OH 43215

Subject: Notice of Violation - Failure to Submit Operational Reports.

A review of our records indicates that the operational report for Sanitary District #4 public water system has not been submitted for February 2007. This failure to submit reports constitutes a violation of the Ohio Administrative Code, Rule 3745-81-31 and Section 6109.12 of the Ohio Revised Code.

The report required to be completed and submitted to Ohio EPA is:

Microbiological Contaminant Monthly Operation Report, EPA form 5001.

The required reports must be completed and submitted to this office by the tenth of the month following the reporting period. All required reports for the reporting period February 2007, must be forwarded to my attention within 15 days.

If you have any questions, please contact me at (614) 728-3864.

Sincerely,

Carolyn O'Neal
Environmental Specialist III
Division of Drinking and Ground Waters
Central District Office

c: Toni Buchanan, DDAGW, CO
Franklin County Health Department
CDO File

CO/nsm 2501003 mor via Feb. 2007

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

